



**NOTES:**

1. IN ADDITION TO THE 90° SWEEPS AT THE HOUSE AND PEDESTAL, ONLY 1 ADDITIONAL 90° SWEEP OR 2-45° SWEEP CAN BE INSTALLED IN THE CONDUIT RUN. CONDUIT SWEEPS CANNOT BE CLOSER THAN 5' FROM EACH OTHER.
2. PAD MOUNTED TRANSFORMER SHALL BE 10 FEET OR MORE FROM BUILDING.
3. LOCATION OF METER BASE SHALL BE APPROVED BY T.P.U.D. ENGINEERING DEPT.

**FIGURE 5-21**

	<p>CONDUIT INSTALLATION GUIDELINES FOR SECONDARY PEDESTALS</p>	
	DATE 11-18-03 DWN. BY <i>Tiffany Lima</i> DWG NAME FIGURE5-21	<p><b>TILLAMOOK P.U.D.</b> <b>OREGON 24 TILLAMOOK</b></p>